

**ADDENDUM# 2
INSTALLATION OF HANDICAP ACCESS RAMP
AT CHARTER OAK ELEMENTARY SCHOOL**

Bid #6159F

July 22, 2010

Dear Vendors:

The Contract Bidding Documents pursuant to Bid # 6159F are hereby revised as follows:


The following is in response to a RFI received:

Q1: The base of the stairs calls for one but none is shown. Ramp wall is a frost wall, no footing needed there?

**A1: No footings are required at the ramp or the stairs.
The base of the stairs should say "frost wall".**

Thank you for your patience, time and consideration.

Sincerely,



Tammy Bradley, CPM, C.P.P.B.
Sr. Buyer

C: Mike Longo, Facilities Manager



TOWN OF WEST HARTFORD 50 SOUTH MAIN STREET
TOWN OF WEST HARTFORD, CT 06107-2431
(860) 561-7470 FAX: 561-7492



Printed on Recycled Paper